



### TEST REPORT

#### Water Sample Analysis

Test Report No : EKO/W-503/261225

Issue Date : 29/12/2025

Issued To : WHITEHALL PUBLIC SCHOOL  
8th Milestone, Bareilly Road,  
Rampur, Uttar Pradesh,  
Pin : 244901

Sample Description : Drinking Water (Potable Water)  
Sample Drawn on : NA  
Sample Drawn by : Given by Client  
Sample Received on : 26/12/2025  
Sampling Location : NA  
Sampling Plan & Procedure : NA  
Sample Quantity : 1.0 Litre  
Environmental Conditions : NA  
Analysis Duration : 26/12/2025 To 29/12/2025  
Remark (if any) : NA

### RESULTS

S. No.	Parameters	Test Methods	Results	Units	Limits as per IS:10500-2012	
					Acceptable	Permissible
1	Colour	IS: 3025 (P-4)-A :2021	BLQ (LOQ-1.0)	Hazen	5	15
2	Odour	IS: 3025 (P-5) : 2018	Agreeable	–	Agreeable	Agreeable
3	Taste	IS: 3025 (P-7) :2017	Agreeable	–	Agreeable	Agreeable
4	Turbidity	IS: 3025 (P-10): 2023	BLQ (LOQ-1.0)	NTU	1	5
5	pH	IS: 3025 (P-11) 2.0: 2022	7.12	–	6.5-8.5	No relaxation
6	Total Hardness (as CaCO <sub>3</sub> )	IS: 3025 (P-21)-A : 2009	168.0	mg/L	200	600
7	Total Alkalinity (as CaCO <sub>3</sub> )	IS: 3025 (P-23): 1986	150.0	mg/L	200	600
8	Chloride (as Cl)	IS: 3025 (P-32)-2.0 : 1988	30.5	mg/L	250	1000
9	Residual Free Chlorine	IS: 3025 (P-26)-C : 2021	BLQ (LOQ-0.1)	mg/L	0.2	1
10	Fluoride (as F)	IS: 3025 (Part - 60) -B : 2008	BLQ (LOQ-0.1)	mg/L	1	1.5
11	Total Dissolved Solids	IS: 3025 (P-16): 2023	260.0	mg/L	500	2000
12	Total Coliform	IS: 15185: 2016	Not Detected	Per 100mL	Should be Not Detectable	

#### Notes:

- The results given above are related to the tested sample, as received & mentioned parameters  
The customer asked for the above tests only.
- This test report will not be generated again, either wholly or in part, without prior written permission of the Laboratory.
- The test samples will be disposed off after 15 days from the date of issue of test report, unless until specified by the customer. Sample received for biological tests will be destroyed after 7 days from the date of issue of test report.
- Responsibility of the Laboratory is limited to the invoiced amount only.
- BLQ=Below Limits of Quantification, LOQ= Limits of Quantification

**\*\*End of Report\*\***

For EKO PRO ENGINEERS PVT. LTD.  
SHIVANGI SINGH RAIZADA  
SECTION INCHARGE MICROBIOLOGY  
(Authorised Signatory)  
SAVE THE ENVIRONMENT

For EKO PRO ENGINEERS PVT. LTD.  
PURNIMA CHAUHAN  
TECHNICAL MANAGER  
(Authorised Signatory)  
SAVE THE ENVIRONMENT